

Serial No
JB9738



Gas safety, total peace of mind

TECHNIGAS MOBILE CATERING VEHICLE/TRAILER SAFETY RECORD



Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.

This Safety Record can be used to document the outcomes of the checks and tests required by The Gas Safety (Installation and Use) Regulations. Gas safe is a registered trade mark of HSE and is used under licence.

Details of Registered Business

Gas Safe Register No 637585

Registered Engineer's Name SB57691

Gas Safe Register Licence Number PBolev

Business TECHNIGAS

Address THE HEATH, CHALDON
CATERHAM

Postcode CR3 5DJ

Contact No 01883 410936

Vehicle/Trailer Details

Vehicle or Trailer (please check relevant box)

Chassis/Serial Number na

or

Reg Number Gazero Trader

Trading Title Hey Spud Ltd

Vehicle/Trailer Owner Details

Name (Mr/Mrs/Miss/Ms) _____

Address 2 Trinity Cottages
Chalgrove Rd

Postcode LUS6WN

Contact No _____

Record Issued by PBolev

Signature: _____

Print Name: PBolev

Received By x

Signature: _____

Date: 15/3/2023

	Appliance Type	Manufacturer	Model	Type of flue	Operating pressure	Operation of safety device(s) <input checked="" type="checkbox"/>	Ventilation satisfactory <input checked="" type="checkbox"/>
1	Fryer	Drummond	Inf004	FL	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
2	Fryer	Drummond	Inf004	FL	37 mbar	Pass <input checked="" type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
3	/	/	/	/	mbar	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>
4	/	/	/	/	mbar	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>

	Visual condition of flue and termination <input checked="" type="checkbox"/>	Flue operation checks <input checked="" type="checkbox"/>	Appliance isolation valve fitted <input checked="" type="checkbox"/>	Is appliance secure <input checked="" type="checkbox"/>	Serviced <input checked="" type="checkbox"/>	Safe to use <input checked="" type="checkbox"/>
1	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
2	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input checked="" type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
3	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>
4	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Pass <input type="checkbox"/> Fail <input type="checkbox"/> NA <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>

Gas installation details

Is the LPG cylinder housing satisfactory? Yes No NA

Is the ECV accessible, labelled and operable? Yes No

Is visible gas pipework including gas hoses satisfactory? Yes No

Is the gas installation gas tight? Yes No

LPG Regulator operating pressure 37.1 mbar

LPG Regulator lock-up pressure 46 mbar

General safety

Is there a fire extinguisher(s) provided? Yes No

Is a fire blanket provided? Yes No

Is the current safety record displayed? Yes No

Is 'Safe use of LPG information' displayed? Yes No

Any Defects Identified	GIUSP classification e.g. AR, ID	Warning/Advice Record insert form serial No.

Remedial Action Taken

ATTENTION

Next safety check due by:

15/3/24